

Supporting Information

Energy-efficient design of downstream separation to produce n-butanol by several heat integrated technologies

Hui Xia, Qing Ye, Shenyao Feng, Jingxing Chen, and Tong Liu*

Jiangsu Key Laboratory of Advanced Catalytic Materials and Technology, School of Petrochemical Engineering, Changzhou University, Changzhou, Jiangsu 213164, China

AUTHOR INFORMATION

*Tel.: +86 519 86330355. Fax: +86 519 86330355. E-mail:

huagonglou508@126.com.

This Supporting Information consists of the following parts

I. Table S1 Basis of economics

II. Table S2. Stream results of stream 10

III. Fig S1. Flowsheet of separation of acetone and ethanol

IV. Fig S2. Sequential iterative optimization procedure of the base process

V. Fig S3. Optimal results of the base process

VI. Table S3. Basic parameters of the Base process

VII. Table S4. Basic parameters of the HI-A process

VIII. Table S5. Basic parameters of the HI-B process

IX. Fig S4. Heat exchanger network (HEN) of the HI-A process

X. Fig S5. Heat exchanger network (HEN) of the HI-B process

XI. Fig S6. Four-column modules for the DWC

XII. Fig S7. Sequential iterative optimization procedure of DWC

XIII. Fig S8. Optimal results of DWC

XIV. Table S6. Detailed parameters of the DWC-SHR process

XV. Table S7. Stream energy loads of the DWC-SHR process

Table S1 Basis of economics

Condensers costs

Heat-transfer coefficient= $0.852\text{ kW}/(\text{K}\cdot\text{m}^2)$

Capital cost= $7296A_c^{0.65}$, where area is in squared meters

Reboilers costs

Heat-transfer coefficient= $0.568\text{ kW}/(\text{K}\cdot\text{m}^2)$

Capital cost= $7296A_R^{0.65}$, where area is in squared meters

Coolers costs

Overall heat-transfer coefficient of the systems with liquid phases on both sides is $0.57\text{ kW}/\text{K}\cdot\text{m}^2$

Capital cost= $7296A_R^{0.65}$, where area is in squared meters

Column vessel costs

Capital cost= $17640 D^{1.066} L^{0.802}$

Where D is using aspen tray sizing while $L=(N_T-1)\times 0.61+6$

Compressor costs

Capital cost= $1293/280\times 1264.75\times (\text{hp})^{0.82}$

Where hp represents the horse power of compressor

Annual steam cost

Steam cost= $C_s\times Q\times 8000\times 3600$

Where $C_s=\$7.72$ per GJ /LP steam (433K)

$C_s=\$8.22$ per GJ /MP steam (457K)

Annual cooling water cost

Cooling water cost= $0.03\times Q_c/(\Delta T_w\times 4.183\times 1000)\times 8000\times 3600$

Electricity costs

Electricity cost= $16.8\times \text{hp}/0.72\times 8000\times 3.6/1000$




Fig. 2. Fermentation broth separation using gas stripping and distillation process.

it can be calculated based on the material balance of the COLUMN I, COLUMN II, COLUMN III and COLUMN IV.

$$F_{S10}=F_{S12}+F_{S16}+F_{S21}+F_{S24}$$

Table S2. Stream results of stream 10

Stream No	Butanol	Acetone	Ethanol	Acetic acid	Butyric acid	water	Total mass flowrate (kg/h)
Option B							
12	0.0000	0.0024	0.0005	0.0000	0.0000	0.0002	0.0031
16	0.0000	0.0000	0.0000	0.0000	0.0062	0.0000	0.0062
21	0.0001	0.0000	0.0000	0.0054	0.0000	0.0000	0.0055
24	0.0048	0.0000	0.0000	0.0000	0.0000	0.0000	0.0048
10	0.0049	0.0024	0.0005	0.0054	0.0062	0.0002	0.0196

Table S2A. Energy consumption of reboilers of Column I, Column II, Column III and Column IV in the literature

Process simulation results	Process specific results
	Option B
Energy consumption rate (kW)	
Reboilers	
Column I	0.0039
Column II	0.0025
Column III	0.561
Column IV	0.7954
Total	1.3628




Fig S1. Flowsheet of separation of acetone and ethanol




Fig S2. Sequential iterative optimization procedure of the base process




Fig S3. Optimal results of the base process

Table S3. Basic parameters of the Base process

Item	Base process			
Distillation Columns				
	C1	C2	LPC	HPC
Reflux Ratio	5.2	0.75	7.9	14
Diameter (m)	1.454	1.949	2.763	1.794
Total Stage (N _T)	24	28	24	38
Feed Tray (N _F)	12	14	13	24
Recycled Feed tray (N _r)	/	/	11	/
Condensers				
C1-C	Heat duty (kW)	2481.69		
	Overall heat-transfer coefficients (kW/K·m ²)	0.852		
	Heat-transfer areas (m ²)	168.39		
C2-C	Heat duty (kW)	1804.51		
	Overall heat-transfer coefficients (kW/K·m ²)	0.852		
	Heat-transfer areas (m ²)	69.92		
LPC-C	Heat duty (kW)	3422.97		
	Overall heat-transfer coefficients (kW/K·m ²)	0.852		
	Heat-transfer areas (m ²)	176.14		
HPC-C	Heat duty (kW)	6578.76		
	Overall heat-transfer coefficients (kW/K·m ²)	0.852		
	Heat-transfer areas (m ²)	60.40		
Reboilers				
C1-B	Heat duty (kW)	2489.88		
	Overall heat-transfer coefficients (kW/K·m ²)	0.568		
	Heat-transfer areas (m ²)	96.59		
C2-B	Heat duty (kW)	1502.18		
	Overall heat-transfer coefficients (kW/K·m ²)	0.568		
	Heat-transfer areas (m ²)	43.96		
LPC-B	Heat duty (kW)	3391.46		
	Overall heat-transfer coefficients (kW/K·m ²)	0.568		
	Heat-transfer areas (m ²)	63.15		
HPC-B	Heat duty (kW)	6592.12		
	Overall heat-transfer coefficients (kW/K·m ²)	0.568		
	Heat-transfer areas (m ²)	712.90		

Table S3. Basic parameters of the Base process (Continued)

Item	Base process		
Heaters			
H1	Heat duty (kW)		560.41
	Overall heat-transfer coefficients (kW/K·m ²)		0.568
	Heat-transfer areas (m ²)		11.59
H2	Heat duty (kW)		417.96
	Overall heat-transfer coefficients (kW/K·m ²)		0.568
	Heat-transfer areas (m ²)		121.42
Coolers			
Coolers1	Heat duty (kW)		25.90
	Overall heat-transfer coefficients (kW/K·m ²)		0.57
	Heat-transfer areas (m ²)		4.05
Coolers2	Heat duty (kW)		130.93
	Overall heat-transfer coefficients (kW/K·m ₂)		0.57
	Heat-transfer areas (m ²)		6.96
Coolers3	Heat duty (kW)		58.33
	Overall heat-transfer coefficients (kW/K·m ²)		0.57
	Heat-transfer areas (m ²)		7.22
Coolers4	Heat duty (kW)		263.14
	Overall heat-transfer coefficients (kW/K·m ²)		0.57
	Heat-transfer areas (m ²)		11.78
Coolers5	Heat duty (kW)		154.05
	Overall heat-transfer coefficients (kW/K·m ²)		0.57
	Heat-transfer areas (m ²)		2.26

Table S4. Basic parameters of the HI-A process

Table S-1: Basic parameters of the HI-A process				
Item	HI-A process			
Distillation Columns				
	C1	C2	LPC	HPC
Reflux Ratio	5.2	0.75	7.9	14
Diameter (m)	1.454	1.949	2.763	1.794
Total Stage (N_T)	24	28	24	38
Feed Tray (N_F)	12	14	13	24
Recycled Feed tray (N_r)	/	/	11	/
Condensers				
C1-C	Heat duty (kW)		2481.69	
	Overall heat-transfer coefficients (kW/K·m ²)		0.852	
	Heat-transfer areas (m ²)		168.39	
C2-C	Heat duty (kW)		1804.51	
	Overall heat-transfer coefficients (kW/K·m ²)		0.852	
	Heat-transfer areas (m ²)		69.92	
LPC-C	Heat duty (kW)		3422.97	
	Overall heat-transfer coefficients (kW/K·m ²)		0.852	
	Heat-transfer areas (m ²)		176.14	
HPC-C	Heat duty (kW)		6578.76	
	Overall heat-transfer coefficients (kW/K·m ²)		0.852	
	Heat-transfer areas (m ²)		60.40	
Reboilers				
LPC-B	Heat duty (kW)		3391.46	
	Overall heat-transfer coefficients (kW/K·m ²)		0.568	
	Heat-transfer areas (m ²)		63.15	
HPC-B	Heat duty (kW)		6592.12	
	Overall heat-transfer coefficients (kW/K·m ²)		0.568	
	Heat-transfer areas (m ²)		712.90	
Heaters				
H2	Heat duty (kW)		263.90	
	Overall heat-transfer coefficients (kW/K·m ²)		0.568	
	Heat-transfer areas (m ²)		10.09	
Self-Heat Exchangers				
E1	Heat duty (kW)		560.41	
	Overall heat-transfer coefficients (kW/K·m ²)		0.568	
	Heat-transfer areas (m ²)		11.59	
E2	Heat duty (kW)		2489.88	
	Overall heat-transfer coefficients (kW/K·m ²)		0.568	
	Heat-transfer areas (m ²)		63.15	
E3	Heat duty (kW)		1502.18	
	Overall heat-transfer coefficients (kW/K·m ²)		0.568	
	Heat-transfer areas (m ²)		712.90	

Table S4. Basic parameters of the HI-A process (continued)

Item		HI-A process
E4	Heat duty (kW)	154.05
	Overall heat-transfer coefficients (kW/K·m ²)	0.57
	Heat-transfer areas (m ²)	11.88
Coolers		
Coolers1	Heat duty (kW)	25.90
	Overall heat-transfer coefficients (kW/K·m ²)	0.57
	Heat-transfer areas (m ²)	4.05
Coolers2	Heat duty (kW)	130.93
	Overall heat-transfer coefficients (kW/K·m ²)	0.57
	Heat-transfer areas (m ²)	6.96
Coolers3	Heat duty (kW)	58.33
	Overall heat-transfer coefficients (kW/K·m ²)	0.57
	Heat-transfer areas (m ²)	7.22
Coolers4	Heat duty (kW)	263.14
	Overall heat-transfer coefficients (kW/K·m ²)	0.57
	Heat-transfer areas (m ²)	11.78

Table S5. Basic parameters of the HI-B process

Item	HI-B process			
Distillation Columns				
	C1	C2	LPC	HPC
Reflux Ratio	5.2	0.75	7.9	17.11
Diameter (m)	1.454	1.949	2.763	1.986
Total Stage (N _T)	24	28	24	38
Feed Tray (N _F)	12	14	13	24
Recycled Feed tray (N _r)	/	/	11	/
Condensers				
C1-C	Heat duty (kW)		2481.69	
	Overall heat-transfer coefficients (kW/K·m ²)		0.852	
	Heat-transfer areas (m ²)		168.39	
C2-C	Heat duty (kW)		1804.51	
	Overall heat-transfer coefficients (kW/K·m ²)		0.852	
	Heat-transfer areas (m ²)		69.92	
LPC-C	Heat duty (kW)		3422.97	
	Overall heat-transfer coeffic+ients (kW/K·m ²)		0.852	
	Heat-transfer areas (m ²)		176.14	
HPC-C	Heat duty (kW)		6578.76	
	Overall heat-transfer coefficients (kW/K·m ²)		0.852	
	Heat-transfer areas (m ²)		60.40	
Reboilers				
HPC-B	Heat duty (kW)		7957.24	
	Overall heat-transfer coefficients (kW/K·m ²)		0.568	
	Heat-transfer areas (m ²)		860.53	
Heaters				
H2	Heat duty (kW)		263.90	
	Overall heat-transfer coefficients (kW/K·m ²)		0.568	
	Heat-transfer areas (m ²)		10.09	
Self-Heat Exchangers				
E1	Heat duty (kW)		560.41	
	Overall heat-transfer coefficients (kW/K·m ²)		0.568	
	Heat-transfer areas (m ²)		11.59	
E2	Heat duty (kW)		2489.88	
	Overall heat-transfer coefficients (kW/K·m ²)		0.568	
	Heat-transfer areas (m ²)		63.15	
E3	Heat duty (kW)		1502.18	
	Overall heat-transfer coefficients (kW/K·m ²)		0.568	
	Heat-transfer areas (m ²)		712.90	
E4	Heat duty (kW)		3391.46	

Overall heat-transfer coefficients ($\text{kW/K}\cdot\text{m}^2$)	0.568
Heat-transfer areas (m^2)	63.15

Table S5. Basic parameters of the HI-B process (continued)

Item	HI-B process	
E5	Heat duty (kW)	154.05
	Overall heat-transfer coefficients ($\text{kW/K}\cdot\text{m}^2$)	0.57
	Heat-transfer areas (m^2)	11.88
Coolers		
Coolers1	Heat duty (kW)	25.90
	Overall heat-transfer coefficients ($\text{kW/K}\cdot\text{m}^2$)	0.57
	Heat-transfer areas (m^2)	4.05
Coolers2	Heat duty (kW)	130.93
	Overall heat-transfer coefficients ($\text{kW/K}\cdot\text{m}^2$)	0.57
	Heat-transfer areas (m^2)	6.96
Coolers3	Heat duty (kW)	58.33
	Overall heat-transfer coefficients ($\text{kW/K}\cdot\text{m}^2$)	0.57
	Heat-transfer areas (m^2)	7.22
Coolers4	Heat duty (kW)	263.14
	Overall heat-transfer coefficients ($\text{kW/K}\cdot\text{m}^2$)	0.57
	Heat-transfer areas (m^2)	11.78




Fig S4. Heat exchanger network (HEN) of the HI-A process




Fig S5. HEN of the HI-B process




Fig S6. Four-column modules for the DWC




Fig S7. Sequential iterative optimization procedure of DWC




Fig S8. Optimal results of DWC

Table S6. Detailed parameters of the DWC-SHR process

Item	DWC-SHR process					
Distillation Columns						
	Top section	Left section	Bottom section	DWC Right section	LPC	HPC
Reflux Ratio	7	/	/	/	7.9	14
Diameter (m)	1.431	1.415	2.207	1.440	2.763	1.794
Total Stage (N_T)	5	10	14	10	24	38
Feed Tray	/	5	/	/	13	24
Side tray	/	/	/	5	/	/
Recycled Tray	/	/	/	/	11	/
Condensers						
	Heat duty (kW)				2959.19	
C1-C	Overall heat-transfer coefficients (kW/K·m ²)				0.852	
	Heat-transfer areas (m ²)				212.66	
Self-Heat Exchangers						
	Heat duty (kW)				154.00	
E1	Overall heat-transfer coefficients (kW/K·m ²)				0.57	
	Heat-transfer areas (m ²)				5.71	
	Heat duty (kW)				326.50	
E2	Overall heat-transfer coefficients (kW/K·m ²)				0.57	
	Heat-transfer areas (m ²)				21.86	
	Heat duty (kW)				186.20	
E3	Overall heat-transfer coefficients (kW/K·m ²)				0.57	
	Heat-transfer areas (m ²)				3.63	
	Heat duty (kW)				3391.50	
E4	Overall heat-transfer coefficients (kW/K·m ²)				0.568	
	Heat-transfer areas (m ²)				959.83	
	Heat duty (kW)				417.90	
E5	Overall heat-transfer coefficients (kW/K·m ²)				0.57	
	Heat-transfer areas (m ²)				18.07	
	Heat duty (kW)				6592.17	
E6	Overall heat-transfer coefficients (kW/K·m ²)				0.568	
	Heat-transfer areas (m ²)				1093.51	
Reboilers						
	Heat duty (kW)				1667.27	
DWC-B	Overall heat-transfer coefficients (kW/K·m ²)				0.568	
	Heat-transfer areas (m ²)				48.72	
Condensers						
	Heat duty (kW)				2959.19	
DWC-C	Overall heat-transfer coefficients (kW/K·m ²)				0.852	
	Heat-transfer areas (m ²)				212.66	

Table S6. Detailed parameters of the DWC-SHR process (Continued)

Item	DWC-SHR process	
Coolers		
Cooler1	Heat duty (kW)	25.2
	Overall heat-transfer coefficients (kW/K·m ²)	0.57
	Heat-transfer areas (m ²)	6.16
Cooler2	Heat duty (kW)	58.3
	Overall heat-transfer coefficients (kW/K·m ²)	0.57
	Heat-transfer areas (m ²)	10.66
Cooler2	Heat duty (kW)	36.70
	Overall heat-transfer coefficients (kW/K·m ²)	0.57
	Heat-transfer areas (m ²)	10.02
Cooler2	Heat duty (kW)	131.10
	Overall heat-transfer coefficients (kW/K·m ²)	0.57
	Heat-transfer areas (m ²)	10.41
Cooler3	Heat duty (kW)	306.50
	Overall heat-transfer coefficients (kW/K·m ²)	0.57
	Heat-transfer areas (m ²)	17.23

Table S7. Stream energy loads of the DWC-SHR process

Stream	Stream type	Supply Tem(□)	Target Tem(□)	Duty(kW)
HPC vapor	Hot	186.4	160	7196.27
HPC Bot	Hot	167.4	70.9	154
HPC Top	Hot	160	30	356.2
DWC Bot	Hot	99.9	30	131.1
LPC vapor	Hot	72.4	56.4	3698
LPC Top	Hot	56.4	30	58.3
DWC Con	Hot	50	49.9	2959.19
DWC Top	Hot	49.9	30	25.2
HPC Reb	Cold	167	167.4	6592.17
HPC Pre	Cold	66.1	159.9	417.9
DWC Reb	Cold	99.6	99.9	1667.27
LPC Reb	Cold	65.7	65.8	3391.5
Preheater	Cold	37	108.9	666.7

